



**ROGER BULLIVANT**

# **Monitoring of the ground temperature of a piled foundation heat exchanger system for a residential building over two heating seasons**

**Chris Wood**

[christopher.wood@nottingham.ac.uk](mailto:christopher.wood@nottingham.ac.uk)



**The University of  
Nottingham**

# The problem:

- Heating, lighting and running the current UK building stock amounts to 50% of the total UK energy consumption. 28% is the domestic sector.
- Heating amounts to over 4/5<sup>th</sup> of the domestic energy requirement
- 1/3 of the housing stock required by 2050 is still to be built.

# The requirement:

- To find methods of reducing carbon emissions of new build residential –

*The Answer: GROUND SOURCE!*

- To find cost effective methods of installing ground loops!

*The Answer: To incorporate the loops into the foundations –ENERGY PILES!.*




# Primary research – ground temperature effects


- ❑ Plot equivalent to two semi detached starter homes or one larger 72sqm detached.
- ❑ 21 piles to 10m. 300mm diameter. 1 x 32mm OD pipe U tube in each pile. Pile separation 1.86 to 2.46m
- ❑ No building – heat rejection system built. Heat loading equivalent to a low energy house of today. Approx 27W/sqm peak
- ❑ Testing to date over two heating seasons and two summer seasons
- ❑ 16 perimeter piles used for heat extraction
- ❑ Maximum heat output from heat pump approximately 5.6kW. At a COP of 3.6, the resultant heat extraction per linear meter of pile is 25W/m.



# Test setup





# Pile and array sensing locations



The University of  
Nottingham



# Heat Rejection apparatus





Rejected Heat via Dry cooler

Temperature of water to the heat pump is stable within  $\pm 0.6\text{deg C}$  i.e. differential range of  $1.2\text{degC}$

# Heat loading

- 27W/sqm at 4.8deg C
- Heat load per month calculated by interpolation with respect to the average outside air temperature





Typical heat pump loading of 50% for a day in November = 78kWh/ day




The University of  
Nottingham







# Heat pump monitored parameters





Period (Date)	Seasonal Performance factor	Heat output (MWh)
04/11/07 to 22/05/08	3.62	17.24
22/05/08 to 19/09/08	3.54	0.80
19/09/08 to 22/04/09	3.40	15.15


# Far field recorded and model calculated ground temperatures across the first heating season (Array location C – far field)



# Change in temperature of the ground (from initial temperature) at sensing locations from pile 11 to far field array location C




# Temperature of pile 11 and far field array location C at various depths




The University of Nottingham



**Change in temperature of the ground (from initial temperature)**  
**at a depth of 5m for sensing locations A,B,J, H, pile 13 and**  
**far field location C**



**Average temperature of the centre of pile 11 in relation to GET and other temperature sensing locations (averages calculated from depths 2.5, 5 and 7.5m)**




# What happens next?

- Important point is how does the ground recover year on year – tests are now into the third heating season
- This summer: Investigations into ground heat recharging utilising summer heat from the roof building fabric:
  - Seasonal Heat energy storage within the ground around the energy piles*
- **UK Residential buildings** – high density of dwellings = lack of ground volume = temperature year on year fall = system efficiency reduction (reducing heat pump COP).



# • Energy Pile Ground Heat Storage Battery





Thank you for listening!

Email:

[christopher.wood@nottingham.ac.uk](mailto:christopher.wood@nottingham.ac.uk)