



## “Flow Temperatures and Heat Pump Performance”

Heat Pump Calculator.

Importance of Flow and Return Temps on COP.





Sub-titled :

Back to basics. Press the reset button

Fabric first

Low water temperatures



# Audience – General Practice M&E Consultants


- As manufacturers of large heat pumps have been collaborating with Minibems with their series of lockdown webinars on dynamic flow controls on district heating systems to minimize flow and return temperatures to ensure that the heat pumps would be working at best possible efficiency levels.
- We are working under an NDA with the UK Coal Authority on their schemes to utilise mine water as a source of thermal energy. On some sites the mine water is at a consistent temperature of 20°C.
- Although this water temperature can be a great benefit, unless the heating system is designed correctly the advantage can easily be lost, with severe impact of the lifetime costs of the scheme if high flow temperatures are needed.

# Heat Pump Selector

- The Solid Energy Heat Pump Selector has been designed to assist with large ( >220kW ) heat pump projects at an early feasibility stage.
- It can provide basic data on dimensions, electrical power requirements and an SCOP figure when anticipated flow and return temperatures are disclosed.
- It can very easily give SCOP figures for set parameters and the impact of both good ground water temperatures and poor flow and return can be demonstrated.
- The Heat Pump Selector has been well received and it is now assisting many designers throughout the UK and Ireland.

# Heat Pump Calculator



“How does dynamic flow control impact on the viability of heat pumps”



We have fixed the heat pump as a LW170 (nominal output 500kW ) with the water source temperature at 10°C. We have varied only the flow and return temperatures to demonstrate the impact on the COP and similar scenarios with water source at 20°C (mine water? )

Water Temp 10°C Flow 85°C Return 75°C COP 2.3

1 Pcs.  
 2,000 MWh  
 30 %  
 1,992 MWh  
 100 %  
 867 MWh  
 2.30  
 170  
 250  
 250 SP  
 Direct calc done



Series Blending

Series and blending low limit set at 60 C

Dansk

English

Heat pump



Heat pump unit total

T flow °C	T return °C	T evap. °C	Heat kW	COPheat	EI power
85	75	7.0	418.7	2.30	182
85	75	7.0	418.7	2.30	182

Heat total kW	EI total	COP total
419	182	2.30
419	182	2.30

# Water Temp 10°C F70°C R60°C COP 3.00

1 Pcs.  
 2,000 MWh  
 30 %  
 2,000 MWh  
 100 %  
 670 MWh  
 2.98  
 170  
 250  
 250 SP  
 Direct calc done



Series Blending

Series and blending low limit set at 60 C

Dansk



English

Heat pump					
T flow °C	T return °C	T evap. °C	Heat kW	COPheat	EI power
70	60	7.0	483.4	2.98	162
70	60	7.0	483.4	2.98	162

Heat pump unit total		
Heat total kW	EI total	COP total
483	162	2.98
483	162	2.98

# Water Temp 10°C F70°C R50°C COP 3.25

1 Pcs.  
 2,000 MWh  
 30 %  
 2,000 MWh  
 100 %  
 616 MWh  
 3.24  
 170  
 250  
 250 SP  
 Direct calc done



Series

Blending

Series and blending low limit set at 60 C

Dansk

English

Heat pump

Heat pump unit total



T flow °C	T return °C	T evap. °C	Heat kW	COPheat	EI power
70	50	7.0	525.5	3.24	162

Heat total kW	EI total	COP total
525	162	3.24



# Water Temp 10°C F70°C R40°C COP 3.50

1 Pcs.  
 2,000 MWh  
 30 %  
 2,000 MWh  
 100 %  
 571 MWh  
 3.50  
 170  
 250  
 250 SP  
 Direct calc done



Series

Blending

Series and blending low limit set at 60 C

Dansk

English

Heat pump



Heat pump unit total

T flow °C	T return °C	T evap. °C	Heat kW	COPheat	EI power
70	40	7.0	567.5	3.50	162
70	40	7.0	567.5	3.50	162

Heat total kW	EI total	COP total
568	162	3.50
568	162	3.50

# Water Temp 10°C F60°C R40°C COP 3.75

1 Pcs.  
 2,000 MWh  
 30 %  
 2,000 MWh  
 100 %  
 533 MWh  
 3.75  
 170  
 250  
 250 SP  
 Direct calc done



Series Blending

Series and blending low limit set at 60 C

Dansk

English

at pump

Heat pump unit total

T flow °C	T return °C	T evap. °C	Heat kW	COPheat	El power
60	40	7.0	564.1	3.75	150
60	40	7.0	564.1	3.75	150



Heat total kW	El total	COP total
564	150	3.75
564	150	3.75

# 10°C SUMMARY-F/R temps-COP-Fuel Cost Reduction

Water Temp °C	Flow Temp °C	Return Temp °C	COP	Electricity 15p/kW	Fuel saving over COP 2.3
10	85	75	2.30	6.52	0.0%
10	85	60	2.64	5.68	12%
10	70	60	3.00	5.00	23%
10	70	50	3.25	4.61	29%
10	70	40	3.50	4.28	34%
10	60	40	3.75	4.00	38%

# Water Temp 20°C F70°C R40°C COP 3.64

1 Pcs.  
 2,000 MWh  
 30 %  
 2,000 MWh  
 100 %  
 550 MWh  
 3.64  
 170  
 250  
 250 SP  
 Direct calc done



Series

Blending

Series and blending low limit set at 60 C

Dansk

English

Heat pump

Heat pump unit total

T flow °C	T return °C	T evap. °C	Heat kW	COPheat	El power
70	40	17.0	567.5	3.64	156
70	40	17.0	567.5	3.64	156

Heat total kW	El total	COP total
568	156	3.64
568	156	3.64

# 20°C SUMMARY – Possible savings



Water Temp °C	Flow Temp °C	Return Temp °C	COP	Electricity 15p/kW	Fuel saving over COP 2.3
20	85	75	2.33	6.48	0.6%
20	70	40	3.64	4.12	36%
20	60	40	3.94	3.8	42%

# 10°C & 20°C SUMMARY – Possible savings

Water Temp °C	Flow Temp °C	Return Temp °C	COP	Electricity 15p/kW	Fuel saving over COP 2.3
10	85	75	2.30	6.52	0.0%
20	85	75	2.33	6.48	0.6%
10	85	60	2.64	5.68	12%
10	70	60	3.00	5.00	23%
10	70	50	3.25	4.61	29%
10	70	40	3.50	4.28	34%
20	70	40	3.64	4.12	36%
10	60	40	3.75	4.00	38%
20	60	40	3.94	3.8	42%

# Air Source – seasonal variation in COP

1 Pcs.  
 3,000 MWh  
 25 %  
 3,000 MWh  
 100 %  
 1,067 MWh  
 2.81  
 250  
 250  
 250 SP  
 Series calc done



Series

Blending

Series and blending low limit set at 60 C

Dansk

English

Heat pump

Heat pump unit total

T flow °C	T return °C	T evap. °C	Heat kW	COPheat	El power
60.0	40	-22.4	887.7	2.35	379
60.0	40	-21.4	887.7	2.38	373
60.0	40	-20.4	887.7	2.42	367

Ventilator kW	Pump kW	Defrost kW	Heat total kW	El total	COP total
11.2	5.5	13.9	874	395	2.21
11.2	5.5	14.6	873	390	2.24
11.2	5.5	15.3	872	384	2.27

# 2020 Version. HP Calculator 220kW – 2.6MW

**Initial setup temperature values for flow and return**

For SP models- max 60 C

Tflow °C	Treturn °C
60	40
60	40
60	40
60	40

For all other models - max 90 C

Tflow °C	Treturn °C
70	40
70	40
70	40
70	40

LW models

Cooling °C
5
5
5
5



Version issued 09072020

Language:

Area:

If changes are done to temperature settings, then press calculate and wait for "Calculation Done" text below button  
After initial setup is done, then SCOP calculations for all models can be done.

Calculation Done



3 Compressor sizes  
80, 170 , 250 kWe

Single, twin and triple  
cascade heat pumps

Propane and isobutane

Water and air source

Compact units for limited  
space.

Calculator contains data for  
72 heat pump options.



# Thermal Store – size calculator




## Background data :



Heat power	2,000 kW
Flow temp.	70 C
Return temp.	50 C
Tank volume	80 m3

## Results:

Flow HP	23.9 kg/sek
	86 m3/h



Anlæg data			Charging		De charging		Cycle
Tank	Flow HP	Flow Town	To tank	Hours +	From tank	Hours -	Hours total
m3	m3/h	m3/h	m3/h	Hours	m3/h	Hours	Hours
80	86	8.6	77.3	1.0	8.6	9.3	10.3
80	86	17.2	68.7	1.2	17.2	4.7	5.8
80	86	25.8	60.1	1.3	25.8	3.1	4.4
80	86	34.4	51.6	1.6	34.4	2.3	3.9
80	86	43.0	43.0	1.9	43.0	1.9	3.7
80	86	51.6	34.4	2.3	51.6	1.6	3.9
80	86	60.1	25.8	3.1	60.1	1.3	4.4
80	86	68.7	17.2	4.7	68.7	1.2	5.8
80	86	77.3	8.6	9.3	77.3	1.0	10.3





Any questions

